

**TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)  
PATIALA**

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala  
researchunitpatiala@yahoo.in

To,

DAV Public School, Badshahpur Mandi,.  
Samana, Patiala

No.: TWERU/2526/00147      Dated : 27/05/2025

Subject :            Testing Reports of Water Samples.

Reference:        Your Letter/SRF No. 057   Dated: 20/05/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 21/05/2025. It is request to fill the attached feedback form and send it back to Trade Waste and Effluents Research Unit (Regional Lab) Patiala

D/A :                Test Report



**Authorized Signatory  
For, Trade Waste and Effluents Research Unit  
(Regional Lab) Patiala**

# TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)

## PATIALA

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala  
researchunitpatiala@yahoo.in

TEST REPORT						
Name & Address of Customer : <b>DAV Public School, Badshahpur Mandi,, Samana, Patiala</b>			Customer Reference No.		No : 057 Dated : 20/05/2025	
			Sample Submitted by			
			Date of Sample Receipt		21/05/2025	
			Analysis Starting Date		22/05/2025	
			Analysis completion Date		27/05/2025	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:		TC142422500000216F		Sample Type :		Water
Test Report No.:		TWERU/2526/00147		Date of Issue :		27/05/2025
Registration no.:		TWERU/REG2526/01135		Condition of Sample :		Unsealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		2000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Submersible at DAV Public School, Badshahpur Mandi , Samana, Patiala. / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Patiala
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.95	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	TDS	500	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
3	Turbidity	2.85	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
4	Alkalinity(CaCO <sub>3</sub> )	400	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
5	Hardness(CaCO <sub>3</sub> )	280	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
6	Calcium(Ca)	42	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
7	Magnesium(Mg)	43	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
8	Fluoride(F)	0.72	1.0	1.5	mg/l	APHA 24th Ed.2023, Method 4110
9	Chloride(Cl)	18	250	1000	mg/l	APHA 24th Ed.2023, Method 4110
10	Nitrate(NO <sub>3</sub> )	2	45	No Relaxation	mg/l	APHA 24th Ed.2023, Method 4110
11	Sulphate(SO <sub>4</sub> )	50	200	400	mg/l	APHA 24th Ed.2023, Method 4110
12	Iron	BDL(0.2)	1	No Relaxation	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS
13	Manganese	BDL(0.1)	0.1	0.3	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS

Continue on next page...

Reviewed and Approved By

Sh. Brij Bhushan  
Quality Manager  
Authorized Signatory  
For, Trade Waste and Effluents Research Unit  
(Regional Lab) Patiala

# TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)

## PATIALA

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala  
researchunitpatiala@yahoo.in

14	Zinc	BDL(0.2)	5	15	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS
15	Arsenic(As)	BDL(0.005)	0.01	No Relaxation	mg/l	APHA 3114 (23rd Ed. 2017) by HVG-AAS
16	Residual Chlorine(RC)	BDL(0.17)	0.2	1	mg/l	IS-3025 (Part-26) by Iodometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit:  $25 \pm 5^{\circ}\text{C}$  and Humidity condition limit:  $50 \pm 20\%$

Reviewed and Approved By

Sh. Brij Bhushan  
Quality Manager  
Authorized Signatory  
For, Trade Waste and Effluents Research Unit  
(Regional Lab) Patiala

----- End of the Test Report -----